



State of Ohio Environmental Protection Agency

STREET ADDRESS:

**Central District Office**

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

June 21, 2010

Mark Demarest  
Maronda Homes Inc  
3811 Twin Creeks Drive  
Columbus, Ohio 43204

**Re: Hunter's Glen / Franklin County**

Dear Mr. Demarest:

This letter is written regarding the storm water inspection that I conducted at the Hunter Glen construction site along Bowen Road in Franklin County on June 16, 2010. **It appears construction has not started at this site.** I understand that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

c: Jeff Bohne,

GS/nm Hunters Glen, June 16, 2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korieski, Director

