



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Cazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 14, 2010

John Donley
Donley, Inc.
7600 Farmsbury Dr.
Reynoldsburg, OH 43068

RE: Meadowmoore, Sec. 3, Ph. 1-4, Fairfield County

Dear Mr. Donley:

This letter is written regarding the storm water inspection that I conducted at Meadowmoore, Sec. 3, Ph. 1-4, located along Milnor Road, on June 8, 2010. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

Overall, the site appeared in compliance with the General Storm Water Permit except for one small area that needs stabilized. The stockpile and surrounding area near the concrete wash pit needs to be re-seeded and stabilized. Please see attached pictures.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office


Enclosure

c: Jeff Bohne, DSW/CDO

GS/nsm Meadowmoore, Sec. 3, Ph. 1-4, June 8, 2010.doc

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





Meadowmoore, Sec. 3, Ph. 1
Stabilize barren areas
Walnut Creek Watershed
June 8, 2010
Photo by: Greg Sanders



Meadowmoore, Sec. 3, Ph. 1
Stabilize barren areas
Walnut Creek Watershed
June 8, 2010
Photo by: Greg Sanders



