



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Osazurus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

June 9, 2010

Victoria Bonner
Rennob / ABL Group
5380 Havenhill Drive
Columbus, OH 43235

Re: Cobbleton Development/ Franklin County

Dear Ms. Bonner:

This letter is written in follow-up to a construction storm water inspection that I conducted at the Cobbleton Development located near the intersection of Ebright Road and Winchester Pike, on June 1, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

There was no active construction during my inspection. No erosion appeared to be leaving the site. If construction does start again, please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Stormwater Section
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GS/nsm Cobbleton Development, June 1, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

