



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 1, 2010

W. Patrick Smith
Flying Horse Farms
2950 East Broad Street
Columbus, OH 43209

Re: Construction Storm Water Inspection at Flying Horse Farms in Morrow CO.

Dear Mr. Smith:

This letter is written in follow-up to a construction storm water inspection I conducted at Flying Horse Farms located in Morrow County on May 21, 2010. The inspection was conducted to evaluate the sediment and erosion controls as required by your General Storm Water Permit Associated with Construction Activities. The following items were noted:

Sediment and Erosion Controls

- The two centralized sediment basins are full and must be restored to the original design capacity. The sediment from the ponds must be removed within seven days from receipt of this letter.
- The perimeter controls must be maintained specifically near the stream on the north end of the project
- Diversions/ Ditches must be established to ensure positive drainage to the ponds intended for sediment control.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days. The required self inspection logs dates of earth disturbing activities to ensure the stabilization requirements are not violated

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



W. Patrick Smith
Flying Horse Farms
Page -2-

- The General Permit requires the permittee to conduct self inspections of the site every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. Logs of all inspections must be available for review upon request. Logs must include date of inspection, authorized representative, all deficiencies, and the date corrective actions were implemented. The logs must also include dates of earth disturbing activities to ensure the permanent and temporary stabilization requirements are not violated.

Post Construction Requirements:

- Please submit to my attention all design criteria to address the post construction requirements of the General Permit. An electronic submittal to harry.kallipolitis@epa.state.oh.us, is preferred.

If you have questions regarding this letter or my inspection, please contact me at 614-728-3844 or at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office