



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2010

Jeremy Hoyt
City of Marysville
125 East Sixth Street
Marysville, OH 43040

**Re: Construction Storm Water Inspection at Industrial Parkway Sewer Extension
Union County
Permit Number 4GCD00060*AG**

Dear Mr. Hoyt:

This letter is written in follow-up to a construction storm water inspection conducted by Stephen Riley and Vinod Tujalpuram of Ohio EPA at **Industrial Parkway Sewer Extension** in Marysville, Ohio on June 29, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- There are multiple stock piles on the northwestern most point of the project area. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.
- There appears to be minimal sediment control on either end of the project area. (Please refer to photos) Sediment traps must be utilized for areas of concentrated flow and must be sized with a required sediment storage volume per the General Permit. These sediment impoundments will require cleaning once they have exceeded 50 percent of their capacity.


Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Jeremy Hoyt
City of Marysville
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

Enclosure

c: Jeff Bohne, Water Quality Supervisor, CDO/DSW

HK/nsm Industrial Parkway Sewer Extension



Figure 1: Lack of Control on northwest of project area



Figure 2: Lack of seeding on finished areas



Figure 3: Lack of controls on southeast portion of project area

