



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Caesar Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 1, 2010

Dan Rogers
Village of Mt. Gilead
72 West High Street
Mt. Gilead, OH 43338

Re: Storm Water Inspection of Sanitary/Storm Improvement Projects in Mt. Gilead

Dear Mr. Rogers:

On May 21, 2010, I conducted a storm water inspection associated with the construction activities of Mt. Gilead Sanitary Sewer Rehabilitation and Storm Sewer Replacement Projects located in Mt. Gilead, Ohio. This construction site appears to be greater than one acre and will require coverage (under 40 CFR 122.26) under the General Storm Water Permit Associated with Construction Activities. Based on the current storm water regulations and my site observations the following items must be addressed in the event the one acre threshold is exceeded:

Storm Water Pollution Prevention Plan (SWPPP):

- A SWPPP must be developed specific for this site. The plan must address all phases of construction and identify the location and sizing of all sediment and erosion controls. Schedules for temporary and permanent seeding must also be addressed in the SWPPP. This plan must be maintained on site for the agency to review. Be Aware Ohio EPA reserves the right to require modifications to the SWPPP if the minimum conditions of the General Storm Water Permit are not met.

Storm Water Permitting Requirements:

- In accordance with 40 CFR 122.26 and OAC 3745-39-04, this facility must seek coverage under the "General Storm Water Permit Associated with Industrial Activities." The general permit is a National Pollutant Discharge Elimination System (NPDES) permit which authorizes the release of storm water associated with your facility. The Notice of Intent (NOI) application and permit can be found at the following address: <http://www.epa.state.oh.us/dsw/storm/stormform.html>. The SWPPP must be developed prior to the submittal of the NOI application.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Dan Rogers
Village of Mt. Gilead
Page -2-

The following measures should be completed within seven day regarding of your permitting requirements:

Sediment and Erosion Controls:

- Additional erosion protection (seed and mulch) is required to fully stabilize the disturbed areas between Catalpa, Willow and Hickory Roads. Please refer to the attached photos for specific locations:

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c. Steve Malone DEFA
Kristy Hunt DEFA

The attached photos depicts areas along Hickory, Willow, and Catalpa, where additional erosion protection is required to ensure full stabilization







