



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 1, 2010

Matt Peoples
Canal Winchester Public Works
36 South High Street
Canal Winchester, OH 43110

Re: Canal Pointe Improvements / Franklin County

Dear Mr. Peoples:

The letter is written regarding the storm water inspection I conducted on May 25, 2010, of the Canal Pointe Improvements located at the end of Dove Parkway. The construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items were noted at the site:

During the inspection, I noted that the construction at the site was nearly complete. No erosion was leaving the site. Most of the site was stabilized, except for a small ditch line that appears to be a recent waterline installation. Please stabilize this ditch line.

The curb inlets covers (dandy bags) may be removed from the curb inlets.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO
Todd Keller, Loveland Excavating

GS/nsm Canal Pointe Improvements, May 25, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

