



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 26, 2010

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit 4GC03083* AG, May 20, 2010**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on May 20, 2010. The purpose of the inspection was to evaluate compliance with your General Storm Water Permit. Kevin Ballog with Smoot Construction was present during the inspection. During the inspection the following items were evaluated:

Sediment and Erosion Controls:

- Areas east of the stream have been seeded and mulched. Sediment ponds must remain until vegetation is established sufficient to control erosion.
- Permanent ponds have been seeded with vegetation becoming established. Skimmers must remain until entire site is protected from erosion.

Post Construction:

- Please verify your post construction measures have been met. Please understand all dry ponds must incorporate a forebay and micro-pool each sized at 10 percent of the water quality volume or demonstrate an approvable alternative.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c. Kevin Ballog, Smoot Construction

HK/nsm Summit Reynoldsburg May 20, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

