



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

W. S. Zarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

May 26, 2010

Stephen Renner  
Franklin County Sanitary Engineer  
280 East Broad Street  
Columbus, OH 43215

**Re: Storm Water Inspection at Little Cleveland Heights Sanitary Sewer Phase 3  
Permit Number 4GC03124\*AG**

Dear Mr. Renner:

This letter is written regarding the storm water inspection I conducted at Cleveland Heights Sanitary Sewer, Phase 3. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

**Sediment and Erosion Controls:**

- Additional erosion protection is required for all remaining barren areas. Specific areas are detailed on the east and west portions of the projects and depicted in the attached photos.
- A significant erosion gully is present at the east end of the project and must be stabilized and protected from erosion.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.


Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Cleveland Heights Sanitary Sewer May 21, 2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director





Cleveland Heights Sanitary Sewer Phase 3  
location: N 40 03' 56.23" W 82 56' 47.8"

Alum Creek Watershed  
Photo by: Harry Kalipolitis  
May 21, 2010

Note: Area requiring additional erosion protection



Cleveland Heights Sanitary Sewer Phase 3  
location: N 40 03' 56.23" W 82 56' 47.6"

Alum Creek Watershed  
Photo by: Harry Kalipolitis  
May 21, 2010

Note: Erosion gully must be stabilized  
Additional erosion protection required for barren areas

