



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 24, 2010

Brad Jones
ODOT District 6
400 East Williams Street
Delaware, OH 43015

**Re: Storm Water Inspection at I-270 Improvement Project
Permit # 4GC02955*AG**

Dear Mr. Jones:

This letter is written in follow-up to a construction storm water inspection I conducted at I-270 Improvement Project located at I-270 between U.S. Route 23 and I-71 on May 7, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- The north facing fill slopes were partially protected from erosion, however, additional erosion protection is expected for all barren areas associated with the northern slopes.

If you have any questions regarding this letter or the inspection, please do not hesitate to call me at our Central District Office at (614) 728-3844.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm ODOT I270 and US23,03-16-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

