



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 19, 2010

Ezekiel Wolfe
Westerman Company
245 North Broad Street
Bremen, OH 43107

Re: Westerman Nuclear Facility / Fairfield County

Dear Mr. Wolfe:

This letter is written regarding the storm water inspection that I conducted on May 13, 2010, at the Westerman Nuclear Facility, located at 1395 Webb Summit Road, in Bremen, Ohio. I met with your contractor, John Seifert, during the inspection. There was recent construction activity at this site. Based on the site inspection and the General Storm Water Permit, the following items were noted during the inspection.

Sediment and Erosion Controls:

The site was stabilized and no erosion was leaving the site. When dewatering, please continue to keep the suction side of the pump/hose off the bottom of the sediment pond.

Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and mulch), this specifically applies to stock piles and barren areas located on the site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO
John Seifert, Seifert Construction, Inc.

GS/nsm Westerman Nuclear Facility, May 13, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



