



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 12, 2010

Ron Strussion
Reynoldsburg City Schools
7244 East Main Street
Reynoldsburg, OH 43068

**Re: New Summit Road High School and Elementary School
Permit 4GC03083* AG, April 16, 2010**

Dear Mr. Strussion:

This letter is written in follow-up to a storm water construction I conducted at Summit Road High School located in Reynoldsburg, Ohio on April 29, 2010. The purpose of the inspection was to evaluate compliance with your General Storm Water Permit. During the inspection the following items were evaluated:

Sediment and Erosion Controls:

- The large regional basin has recently been seeded. Please continue to monitor these efforts to ensure effective erosion control.
- The temporary sediment basins which control the ball fields east of the small stream must be de-watered in between storm events or installed an outlet structure in accordance with the permit requirements.
- The post construction requirements mandate a fore bay and micro pool each sized at 10 percent of the water quality volume. Please demonstrate the measure will be implemented or demonstrate an approvable alternative.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c. Kevin Ballog, Smoot Construction

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

HK/nsm Summit Reynoldsburg 4-29-2010



