



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 12, 2010

Jerry Berms
Licking County
20 South Second Street
Newark, OH 43055

Re: Etna Parkway 4GC00548*AG

Dear Mr. Berms:

This letter is written in follow-up to a construction storm water inspection I conducted at Etna Parkway on April 30, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following issues associated with construction activities north of Refugee Road.

Sediment and Erosion Control:

- Additional seed and mulch was implemented in the ditch line associated with the project
- Check dams were re-installed.
- The temporary ditch, towards the center of the project, was filled and stabilized.
- The main line has not been protected from erosion. All areas must be protected to ensure compliance with the General Permit.
- Excavated sediment basins, in addition to the check dams, must be installed in accordance with the approved plan to ensure compliance.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



For H.K.

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



