



State of Ohio Environmental Protection Agency

**STREET ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

May 10, 2010

Jason Gunsorek  
Anchor Companies  
7760 Olentangy River Road #112  
Columbus, OH 43235

**Re: White Oak Commercial Center / Franklin County**

Dear Mr. Gunsorek:

This letter is written regarding the storm water inspection that I conducted at the White Oak Commercial Center located along Gender Road, on May 3, 2010. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. The following was noted during my inspection:

**Sediment and Erosion Controls:**

There did not appear to be any construction activity at the site. The site was stabilized and no erosion was leaving the site. Please be aware that if construction activities commence that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Storm Water Unit  
Division of Surface Water  
Central District Office

GS/nsm White Oak Commercial Development, May 3, 2010

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director



