



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 10, 2010

Todd Garwick
City of Dublin
5800 Shier-Rings Road
Dublin, OH 43016

**Re: Storm Water Inspection of Sanitary Sewer Installation on State Route 161
Permit Number: 4GC03207*AG**

Dear Mr. Garwick

This letter is written in follow up to a construction storm water inspection I conducted at sanitary sewer installation located adjacent to State Route 161 in Dublin, Ohio on April 21, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, I noted the following:

Sediment and Erosion Controls:

- During the inspection, I noted the majority of the site was void of any effective sediment and erosion controls. Corrective measures are expected within three days from receipt of this letter to implement controls to minimize off-site sedimentation.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us. In addition, please provide a written response to this letter within seven days of receipt.

Sincerely

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm Sanitary Sewer 161 Dublin, 4-23-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

