



State of Ohio Environmental Protection Agency

STREET ADDRESS:

W. Zazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 10, 2010

Doug Carpenter
Jonathan Alder Schools
9200 US Route 42
South Plain City, OH 43064

**Re: Construction Storm Water Inspection at Canaan Middle School
Permit Number 4GCD00064*AG**

Dear Mr. Carpenter:

This letter is written in follow up to a construction storm water inspection I conducted at Plain City Elementary School, located in Plain City, Ohio, on April 21, 2010. The purpose of the inspections was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities within the Bid Darby Watershed. During the inspections, I noted the following:

Sediment and Erosion Controls:

- The two sediment basins have been installed. Only one of the basins incorporates a skimmer device to ensure effective sediment control. It was my understanding the second skimmer will be installed within seven days from the day of my inspection. Please ensure all skimmers are installed and properly maintained to ensure the intended function. It is imperative the skimmers are inspected routinely to ensure an effective seal to the outlet structure. I expect this observation is logged in your self-inspection reports.

Maintenance Inspections:

- The General Permit requires the permittee to conduct self inspections of the site every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. Logs of all inspections must be available for review upon request. Logs must include date of inspection, authorized representative, all deficiencies, and the date corrective actions were implemented. The logs must also include dates of earth disturbing activities to ensure the permanent and temporary stabilization requirements are not violated.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Monitoring Requirements:

- The General Permit requires specific effluent monitoring of all sediment basins associated with this site. Please ensure the monitoring requirements are addressed. At this time, I am formally requesting the submittal of the results for my review.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office