



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

May 6, 2010

Floyd E. Wicks
Rockmill Development Corp.
4920 E. Fifth Ave.
Columbus, Oh 43219

Dear Mr. Wicks:

This letter is written regarding storm water inspection I conducted of the construction activities at Misty Meadows, located in Fairfield County, on April 30, 2010. I understand this site is currently covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the conditions set forth in the General Permit, the following items must be addressed:

Sediment and Erosion Controls:

There appeared to be several homes under construction during the time of the inspection. The sites needed attention with regards to their erosion controls. Additional silt fence or straw wattles needed to be installed. Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity. Please see attached pictures.

I noted a concrete wash out containment pit on-site.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Storm Water Section
Division of Surface Water
Central District Office


Enclosure

c: Jeff Bohne, DSW/CDO
James Pate, City of Lancaster
Chris Phelps, Maronda Homes

GS/nsm Misty Meadows, April 30, 2010

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director





**Misty Meadows
Install erosion controls
Hocking River Watershed
April 30, 2010
Photo by: Greg Sanders**

