



State of Ohio Environmental Protection Agency

REET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

June 30, 2010

David Johnson
ODOT Dist 5
9600 Jackson Town Road
Jacksontown, OH 43030

**Re: Storm Water Inspection of State Route 16 Improvements in Newark, Ohio.
Permit Number 4GC02949*AG**

Dear Mr. Johnson:

This letter is written regarding the storm water inspection I conducted of the State Route 16 Improvements through Newark, Ohio on May 26, 2010. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Control:

- During the inspection, I noted milling operations associated with this improvement project. Currently, there is minimal land disturbing activity, as a result, sediment erosion controls have yet to be implemented for the site.
- Please ensure all sediment and erosion controls associated with future land disturbing activities are implemented in accordance with your permit conditions.

If you have any question regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. A follow-up inspection will be conducted to ensure the conditions of the General Permit are met.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

HK/nsm ODOT Dist 5, SR 16 Improvements 5-26-10

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



