



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

November 15, 2010

Letty Schamp
City of Hilliard
3800 Municipal Way
Hilliard, OH 43026

**Re: Construction Storm Water Inspection at Main Street Improvement Project
Permit Number 4GC02591*AG**

Dear Mr. Schamp:

This letter is written in follow-up to a construction storm water inspection I conducted of the constructions activities associated with the Main Street Improvement Project in Hilliard, Ohio on November 4, 2010. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, our staff noted the following issues associated with construction activities at this site:

Sediment and Erosion Control:

- The project appears in the final stages of construction. In addition there are significant areas which appear to be at final grade. All barren areas at final grade will require protection from erosion within seven days from receipt of this letter.

Post Construction Requirements:


- The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at:
<http://www.epa.state.oh.us/dsw/storm/CGPPCQA.aspx>. Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Letty Schamp
City of Hilliard
Page -2-

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3844 or email at harry.kallipolitis@epa.state.oh.us.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Main St. Improvements Hilliard 11-04-10