





**Environmental
Protection Agency**

Ted Strickland, Governor
Lee Fisher, Lt. Governor
Chris Korfeski, Director

Re: Hardin County
Ohio Fresh Eggs, LLC-Mt Victory
PWS ID#OH3335112
STU ID#: 3354929

November 18, 2010

Mr. Joe Laffoon, Administrative Contact
10513 Croton Rd
Johnstown, OH 43301

Dear Mr. Laffoon:

The Plant – Distribution Monthly Operation Report (EPA Form 5002) for the October 2010 monitoring period reported free chlorine residual of less than two-tenths milligrams per liter (mg/l) and combined chlorine residual of less than one mg/l in the distribution system on October 3, 11, 12, 13, 14, 23, 24, 25, 26, 27 and 31, 2010. An investigation is recommended with the findings reported to my attention.

The report also failed to report analytical information for Chlorine Residual (Total). "Instructions For Completing The Water Plant/Distribution System Monthly Operating Report" are available via the internet at http://www.epa.ohio.gov/portals/28/documents/reporting/DailyMORInstructions_for_PWS_5002.pdf

Section 3 (aa) (page 10) provides specific instructions pertinent to this issue.

Questions may be directed to my attention by contacting me at 419-373-3042 or via e-mail to Larry.Moritz@epa.state.oh.us.

Sincerely,

Larry Moritz, R.S., M.S.I.H.
Division of Drinking and Ground Waters

/lb

pc: David Fabian, Operator of Record
Sheryl Logue, Compliance Administration
Hardin County Health Department
DDAGW/NWDO

(

(

Page 1