



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

NOTICE OF VIOLATION

February 29, 2012

Re: Williams County
Williams County Garage
Class A Water Supply
PWS ID: OH8634812

Williams County Garage
Willis Allomong
12953 County Rd G
Bryan, OH 43506

Reference: No Operator of Record

A review of our files indicates your operator of record Willis Allomong's Class A Water Supply certificate became invalid on December 31, 2011. An operator with an invalid certificate may not act as the operator of record for a facility. Based on this information, your public water system (PWS) is operating without an appropriately certified operator of record which is a violation of Ohio Administrative Code (OAC) 3745-7-02(A)(1). OAC Rule 3745-7-02(A)(1) states: "the owner or operator of a public water system shall designate an operator of record with a certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant".

Your facility is a Class A PWS without treatment, therefore a Class A or higher operator must be physically present at the facility for a period of 30 minutes per week. In order to address the above referenced violation, the following actions shall be taken:

1. Obtain an operator of record to be the on-site certified operator who performs the technical operation of the water treatment plant within the public water system; and
2. Complete the enclosed Operator of Record Notification Form. Mail or fax the form to the address listed at the top of the form, **15 days from the date of this letter.**

In the event you need assistance in finding an appropriately certified operator you may use Ohio EPA's Contract Operator's List at the following link to assist you:

http://epa.ohio.gov/portals/28/documents/opcert/contract_operator_list.pdf

If you should have any questions, please contact **Dave Riley** or **Mike Santone** at (614) 644-2752

Sincerely,

Andrew Brienbrock, Environmental Supervisor
Division of Drinking and Ground Waters
Enclosure: Operator of Record Notification form

cc: Ralph Baker NWDO - DDAGW
File