



**Environmental  
Protection Agency**

John R. Kasich, **Governor**  
Mary Taylor, **Lt. Governor**  
Scott J. Nally, **Director**

**NOTICE OF VIOLATION**

February 14, 2012

Re: Washington County  
Oak Grove Complex PWS  
Class 1  
PWS ID: OH8447112

Mr. Anthony Long  
Oak Grove Complex  
282 BF Goodrich Road  
Marietta, Ohio 45750

Reference: No Operator of Record

A review of our files indicates your public water system (PWS) is operating without an appropriately certified operator of record which is a violation of Ohio Administrative Code (OAC) Rule 3745-7-02(A)(1). OAC Rule 3745-7-02 (A)(1), states, "the owner or operator of a public water system shall designate an operator of record with a certification of a class equal to or greater than the classification of the public water system, distribution system or water treatment plant."

Your facility is a Class 1 PWS, therefore a Class 1 or higher operator must be physically present at the facility for a period of 3 days per week and a minimum of 1.5 hours per week. In order to address the above referenced violation, the following actions shall be taken:

1. Obtain an operator of record to be the on-site certified operator who performs the technical operation of the public water system or each water treatment plant and distribution system within the public water system. The operator of record must be physically present at the public water system 3 days per week for a minimum of 1.5 hours per week; and
2. Complete the enclosed Operator of Record Notification Form. Mail or fax the form to the address listed at the top of the form no later than **15 days from the date of this letter**.

In the event you need assistance in finding an appropriately certified operator you may use Ohio EPA's Contract Operator's List at the following link to assist you:

[http://epa.ohio.gov/portals/28/documents/opcert/contract\\_operator\\_list.pdf](http://epa.ohio.gov/portals/28/documents/opcert/contract_operator_list.pdf)

If you should have any questions, please contact **Dave Riley** or **Mike Santone** at (614) 644-2752.

Sincerely,

Andrew Barenbrock, Environmental Supervisor  
Division of Drinking and Ground Waters

Enclosed: Operator of Record Notification Form

cc: Southeast District Office, DDAGW  
File