



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



February 21, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Charles D Williams  
9944 Wilkshire Boulevard  
Bolivar, OH 44612

Tuscarawas County  
TCMSD-Ridgewood PWS  
COMMUNITY PWS  
PWS ID: OH7901912

Dear Public Water System Owner:

The TCMSD-RIDGEWOOD PWS is in violation of the Ohio Administrative Code (OAC) for failing to maintain chlorine residuals as required by OAC 3745-83-01 for the months of October and December 2011.

Chlorine for Community PWS (frequency and concentration)

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system.

October 2011:

Chlorine residual samples for the month of October 2011 had 5 days during the month that fell below 0.2 mg/L Free and 1.0 Combined for the distribution system and 1 day for the treatment plant.

Chlorine residual samples for the month of December 2011 had 7 days during the month that fell below 0.2 mg/L Free and 1.0 Combined for the distribution system and 1 day for the treatment plant.

If you have any questions please call me at 740-380-5229.

Sincerely,

Russell Flagg, REHS  
Environmental Specialist 3

RF/cb

ec: SEDO DDAGW AA (State Violation)

Southeast District Office  
2195 Front Street  
Logan, OH 43138-8637

740 | 385 8501  
740 | 385 6490 (fax)  
www.epa.ohio.gov