



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



February 21, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Charles D Williams
9944 Wilkshire Boulevard
Bolivar, OH 44612

Tuscarawas County
TCMSD-Wilkshire Hills PWS
COMMUNITY PWS
PWS ID: OH7901612

Dear Public Water System Owner:

The TCMSD-WILKSHIRE HILLS PWS is in violation of the Ohio Revised Code (ORC) for exceeding the limits established for fluoride as required by ORC 6109.20.

Fluoride:


This letter is notice that the TCMSD-Wilkshire Hills public water system is in violation of Ohio Revised Code Section 6109.20 for failure to provide a treated water fluoride level of 0.8 to 1.3 mg/l.

October 2011:

The level of fluoride exceeded the 1.3 mg/l maximum 4 times during the month. There was one instance of the level being below 0.8 for the day during the month.

If you have any questions please me at 740-380-5229.

Sincerely,



Russell Flagg, REHS
Environmental Specialist 3

RF/cb

ec: SEDO DDAGW AA (State Violation)