



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



April 2, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

TCMSD-Wilshire Hills PWS
c/o Charles Williams
9944 Wilshire Boulevard
Bolivar, OH 44612

Tuscarawas County
TCMSD-Wilshire Hills PWS
COMMUNITY PWS
PWS ID: OH7901612

Dear Public Water System Owner:

The TCMSD-WILKSHIRE HILLS PWS is in violation of the Ohio Administrative Code (OAC) for fluoride readings submitted on the February 2012, Monthly Operating Report (MOR) as required by OAC 3745-83-01 (I) and/or OAC 3745-81-75.

Fluoride violation for February 2012:

- Fluoride was outside the required range of 0.8 to 1.3 mg/L for 4 days during the month of February in violation of the Ohio Revised Code 6109.20. Fluoride levels must always be in the range of 0.8 to 1.3 mg/L for optimum dental health.

Please take prompt action to correct these reporting deficiencies in your next operational reports.
Frequency Violation for Fe, Mn and hardness:

If you have any questions please call me at 740-380-5229.

Sincerely,

Russell Flagg

RF/cb

ec: SEDO DDAGW AA (State Violation)