



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

FILE COPY

June 30, 2011

James Channell
Camp Superintendent
Camp Christian
10299 Maple Dell Road
Marysville, OH 43040

Re: **Camp Christian**
NPDES Permit 4GS00010/ OHGS00010
Reconnaissance Inspection
Union County
Notice of Violation

Dear Mr. Channell:

On June 15, 2011, a Reconnaissance Inspection was conducted at the Camp Christian waste water treatment plant (WWTP). Present for the inspection were John Kincaid, the operator for the WWTP, and myself of the Ohio EPA, Central District Office, Division of Surface Water. The purpose of the inspection was to evaluate compliance with the terms and conditions of your NPDES permit and to evaluate the operation and maintenance of the plant.

This letter also serves as a **Notice of Violation** as the facility is operating with an expired NPDES permit.

Findings:

1. The facility is currently operating with an expired NPDES permit. A renewal permit application was not received. **Please submit a Notice-of-Intent (NOI) by July 31, 2011.**

The general permit you will be applying for is the Small Sanitary Discharges (OHS00003). The application for the NOI can be found here:
http://www.epa.state.oh.us/portals/35/documents/NOI_form2_fis.pdf

The instructions for filling the NOI can be found here:
http://www.epa.state.oh.us/portals/35/documents/NOI_instructions2_s.pdf

I notified Mr. Kincaid about this issue via phone and e-mail on June 23, 2011, and informed told him which form to fill out as well.

2. Attached is a table of code violations. This office has received adequate response.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

James Channell
Camp Superintendent
Camp Christian
Page -2-

Attached is the Reconnaissance Inspection Report. The only action item is the requirement to submit an NOI. If you have any questions or comments concerning the enclosed inspection report or renewing the permit, please contact me at (614) 728-3846 or e-mail at cole.miller@epa.ohio.gov.

Sincerely,

A handwritten signature in cursive script that reads "Cole Miller".

Cole Miller
Environmental Specialist
Field Operations Unit
Division of Surface Water
Central District Office

Ec: John Kincaid

CM/nsm 6-15-11 Camp Christian Recon

NPDES Compliance Inspection Report

SECTION A: NATIONAL DATA SYSTEM CODING				
Permit #	NPDES #	Inspection Type	Inspector	Facility Type
4GS00010	OHGS00010	RI	S	2
Inspection Date	Entry Time	Exit Time	Notice of Violation	Significant Non-Compliant
6/15/2011	10:30 AM	11:00 AM	Yes	No

SECTION B: FACILITY DATA	
Name and Location of Facility Inspected	Permit Effective Date
Camp Christian 10299 Maple Dell Road Marysville, Ohio 43040	Permit Expiration Date
Name(s) and Title(s) of On-Site Representatives	Phone Numbers
John Kincaid, Operator	(740) 386-3768
Name and Title of Responsible Official	Phone Number
James Channell, Camp Superintendent	(937) 348-2215

SECTION C: AREAS EVALUATED DURING INSPECTION		
Key: S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated		
U	NPDES Compliance	The permit is expired.
S	Operations & Maintenance	
S	Facility Site Review	
N	Collection System	
S	Flow Measurement	
N	Receiving Waters	
N	Laboratory	

Comments: The facility is operating with an expired permit. An NOI should be submitted as soon as possible.

Signatures	
 6/24/11	 6/24/11
Cole Miller, Inspector Compliance & Enforcement Division of Surface Water Central District Office	Erin Sherer, Reviewer Compliance & Enforcement Supervisor Division of Surface Water Central District Office

Compliance Data for Camp Christian between 1/1/2008 to 6/1/2011

Summary

Permit Effluent Limit Violations: 0
 Permit Effluent Code Violations: 0
 Permit Effluent Frequency Violations: 6
 Compliance Schedule Violations: 0

Frequency Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
June 2010	001	Total Suspended Solids	1/Year	1	0	06/01/2010
June 2010	001	Nitrogen, Ammonia	1/Year	1	0	06/01/2010
June 2010	001	Fecal Coliform	1/Year	1	0	06/01/2010
June 2010	001	CBOD 5 day	1/Year	1	0	06/01/2010
June 2010	001	Chlorine, Total Residu	1/Year	1	0	06/01/2010
June 2010	001	Dissolved Oxygen	1/Year	1	0	06/01/2010

Flow Data for Camp Christian between 1/1/2008 and 6/1/2011

	Date	Flows (GPD)
Ten Highest Flows	5/4/2011	9800
	4/20/2011	7040
	4/21/2011	7040
	5/3/2011	5620
	5/27/2011	5040
	4/26/2011	4400
	5/26/2011	3990
	5/20/2011	3800
	5/28/2011	3780
	7/18/2009	3750
Average Flow Rate		924