



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

FILE COPY

September 13, 2011

Roger Jones, Environmental Manager
Ohio Air National Guard 121 ARW
7370 Minuteman Way
Columbus, OH 43127

**Re: Ohio Air National Guard 121 ARW
NPDES Permit 4IN00180/ OH0124095
Reconnaissance Inspection
Franklin County**

Dear Mr. Jones:

On August 17, 2011, a Reconnaissance Inspection was conducted at the Ohio Air National Guard 121 ARW. Present for the inspection were you and Janice Church, the environmental managers, and myself of the Ohio EPA, Central District Office, Division of Surface Water. The purpose of the inspection was to evaluate compliance with the terms and conditions of your NPDES permit and to evaluate the operation and maintenance of the plant.

Findings:

1. Attached is the compliance data between July 2006 and July 2011. The facility has a relatively good record and no additional response is needed for the attached tables.
2. The facility appeared to employ good practices and there were no visual signs of any pollutants entering the stream. There were markers for both outfalls as well.

Attached is the Reconnaissance Inspection Report. There are no items which require a response. If you have any questions or comments concerning the enclosed inspection report, please contact me at (614) 728-3846 or e-mail at cole.miller@epa.ohio.gov.

Sincerely,

Cole Miller
Environmental Specialist
Field Operations Unit
Division of Surface Water
Central District Office

CM/nsm 8-17-11 Ohio National Air Guard Recon

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov


NPDES Compliance Inspection Report

SECTION A: NATIONAL DATA SYSTEM CODING				
Permit #	NPDES #	Inspection Type	Inspector	Facility Type
4IN00180	OH0124095	RI	S	2
Inspection Date	Entry Time	Exit Time	Notice of Violation	Significant Non-Compliance
8//2011	9:10 AM	10:10 AM	No	No

SECTION B: FACILITY DATA	
Name and Location of Facility Inspected	Permit Effective Date
Ohio Air National Guard 121 ARW 7370 Minuteman Way Columbus, OH 43127	5/1/2011
	Permit Expiration Date
	4/30/2016
Name(s) and Title(s) of On-Site Representatives	Phone Numbers
Roger Jones Janice Church	
Name and Title of Responsible Official	Phone Number
Roger Jones, Environmental Manager	(614) 492-5411

SECTION C: AREAS EVALUATED DURING INSPECTION	
Key: S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated	
S	NPDES Compliance
S	Operations & Maintenance
S	Facility Site Review
S	Collection System
S	Flow Measurement
S	Receiving Waters
N	Laboratory

Comments:

Signatures			
	8/31/11		9/2/11
Cole Miller, Inspector Compliance & Enforcement Division of Surface Water Central District Office	Date	Erin Sherer, Reviewer Compliance & Enforcement Supervisor Division of Surface Water Central District Office	Date

Compliance Data for Ohio Air National Guard 121 ARW between 7/1/2006 to 7/1/2011

Summary

Permit Effluent Limit Violations: 4
 Permit Effluent Code Violations: 0
 Permit Effluent Frequency Violations: 0*
 Compliance Schedule Violations: 0

Limit Violations						
Reporting Period	Station	Parameter	Limit Type	Limit	Reported Value	Violation Date
February 2010	014	Oil and Grease, Total	30D Conc	15	378.	2/1/2010
February 2010	601	Oil and Grease, Total	30D Conc	15	365.	2/1/2010
February 2010	014	Oil and Grease, Total	1D Conc	20	378.	2/23/2010
February 2010	601	Oil and Grease, Total	1D Conc	20	365.	2/23/2010

Frequency Violations						
Reporting Period	Station	Parameter	Sample Frequency	Expected	Reported	Violation Date
August 2007	014	Propylene Glycol, Total	1/Quarter	1	0	08/01/2007

*Propylene Glycol was non detect (<5,000 µg/L) based on records

*The facility has 3 missing data reports.

Station	Required Report Period	DMR Received
014	August 2006	No
601	November 2006	No
014	February 2007	No