



State of Ohio Environmental Protection Agency

FILE COPY

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

November 30, 2009

Mr. Gary Northup
Carter's Mobile Home Park
3001 Northup Avenue
South Bloomfield, OH 43103-1080

**Re: 4PV00108/OH012158
CARTERS MHP WWTP
RECONNAISSANCE INSPECTION
FRANKLIN COUNTY**

Dear Mr. Northup:


Enclosed is the Reconnaissance Inspection Report for the Carters MHP wastewater treatment plant (WWTP). This inspection was conducted on November 12, 2009, by Ohio EPA personnel. At the time of the inspection the WWTP was operating satisfactorily.

After review of your compliance history and your current NPDES permit conditions, this office has the following requirements:

1. The old WWTP was still not properly abandoned, please demolish and permanently cover the area.
2. Your cooperation with this agency's technical assistance program has led to manual addition of lime. If in the future this does not correct the problem, as per your NPDES permit, a permit to install application to correct for the effluent violations shall be enforced.
3. Review the frequency and volume of sludge to remove to avoid further total suspended solids violations.

Should you have any questions, you can reach me at 614-728-3847.

Sincerely,



Sherree Gossett-Johnson
Environmental Specialist II
Enforcement and Compliance
Division of Surface Water
Central District Office

Enclosure

c: Paul Wenning, Franklin County Board of Health

SGJ/nsm Carters MHP 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



NPDES COMPLIANCE INSPECTION REPORT

Section A: National Data System Coding

Permit #	NPDES	Mo/Day/Yr	Insp. Type	Inspector	Fac Type
4PV00108	OH012158	11/12/2009	R	S	1

Section B: Facility Data

Facility Name: Carters MHP
Address: 2500 Harrisburg Pike
City/State/Zip: Grove City, Ohio 43123

Entry Time: 1:30 pm Permit Eff. Date: ^08/01/07
Exit Time: 2:30 pm Permit Exp. Date: ^7/31/12

On-Site Representatives

Name: Gary Northup
Title: Owner
Phone: (614) 539-9900

Responsible Official

Name/Title: Same as above
Address:
Phone:

Section C: Areas Evaluated During Inspection:
(S=Satisfactory, M=Marginal, U=Unsatisfactory, N=Not-Evaluated)


Permit	M	Effluent/ Receiving Waters	S
Records/Reports	S	Sludge Storage/ Disposal	S
Operations & Maint.	M	Pretreatment	S
Facility Site Review	S	Compliance Schedules	S
Collection System	N	Self-Monitoring Program	S
Flow Measurement	S	Other	
Laboratory	S		

Section D: Summary of Findings/Comments:

See cover letter

Name of Inspector: Sheree Gossett-Johnson

Ohio EPA, Central District Office

Signature: 

Date: 11/23/09

Name of Reviewer: Erin Sherer

Ohio EPA, Central District Office

Signature: 

Date: 11/30/09

