

SIGNATURE RECEIVED
OhioEPA

12/14/08 4PA00002
FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED #91 7108 2133 3932 4450 1376

December 8, 2008

Honorable Mayor Joseph Haney
Village of South Solon
P.O. Box 360
South Solon, OH 43153

Re: 4PA00002/OH0021458
VILLAGE OF SOUTH SOLON WWTP
NPDES PERMIT VIOLATION
MADISON COUNTY

Dear Mayor Haney:

We are in receipt of your response letter to my October inspection inquiries. Due to those responses, you are in violation of your NPDES permit. If you do not correct these violations, escalated enforcement may be taken.

Please submit, to this office, within 15 days, your corrective actions to the following:

1. The on-site sampler unit was not operational, resulting in NPDES effluent violations. As per your NPDES Part III, 3. Facility Operation and Quality Control, A. "At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit."
2. Using the water plant meter for wastewater treatment discharge volume is not valid. As per your NPDES Part III, 3. see above and Part III 29. Other Information A. "Where the permittee becomes aware that it failed to submit relevant facts in a permit application or submitted incorrect information on a permit application or in any report to the Director, it shall promptly submit such facts or information"


Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit and/or DFFOs may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Honorable Mayor Joseph Haney
Village of South Solon
Page -2-

If you have any questions feel free to contact me at (614) 728-3847.

Sincerely,

A handwritten signature in black ink, appearing to read 'Sheree Gossett-Johnson', with a long horizontal flourish extending to the right.

Sheree Gossett-Johnson
Environmental Specialist II
Compliance/Enforcement Section
Division of Surface Water

c: Bridget Marchio OEPA/CDO/DDGW

SGJ/nsm South Solon Violation Letter08