

SIGNATURE RECEIVED
OhioEPA

4PB00108
6/30/08
FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

CERTIFIED #91 7108 2133 3932 4450 4032

June 19, 2008

Mr. Terry Jackson
Village of Jeffersonville
4 North Main Street
Jeffersonville, OH 43153

Re: 4PB00108 / OH0136191
Operator Certification Violation
Jeffersonville WWTP
Fayette County


Dear Mr. Jackson:

This office has not received any contract between the Village and your Class I wastewater treatment plant temporary operator replacement. As per the certification rules, 3745-07-04 (B), the minimum time spent by a Class I operator at a Class II wastewater treatment plant (WWTP) is 3 non-consecutive days and at least 1.5 hours per week.

At this time, to avoid escalated enforcement action, please submit, within 10 days of receipt of the violation letter, signed contracts' between the Village and the Class I WWTP operator.

If you have any questions or comments, please contact me at (614) 728-3847.

Sincerely,



Sheree Gossett-Johnson
Environmental Specialist II
Compliance and Enforcement Section
Division of Surface Water
Central District Office

SGJ/nsm Jeffersonville compliance letter again 2008

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director