

4PC 00101



State of Ohio Environmental Protection Agency

FILE COPY

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 8, 2008

C. Joe Allen
Superintendent
Village of South Bloomfield
5023 Union Street
South Bloomfield, OH 43103

Re: 4pc00101/Oh00130991
South Bloomfield WWTP
Compliance Review
Pickaway County


Dear Mr. Allen:

This office has been concerned that the flooded man holes along Mud Run allows clean water into the collection system. As a separately sewerred community, allowing clean water into its sanitary sewer collection system is illegal, causes wastewater plant upset, and ultimately leads to the degradation of Mud Run.

To avoid escalated enforcement, please proceed with elevation of the manholes to assure that flooding does not occur.

If you have any questions, comments, or concerns, please call me at (614) 728-3847.

Sincerely,


Sheree Gossett-Johnson
Environmental Specialist II
Compliance and Enforcement Unit
Division of Surface Water
Central District Office

SGJ/nsm South Bloomfield MH

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director