

4PV001056



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

RECEIVED

JUN 22 2009

OHIO EPA/CDO

CERTIFIED #91 7108 2133 3932 4449 8751

June 18, 2009

Paul Bogenrife
Pickett Fences
1161 Durbridge Road
Columbus, OH 43229

**Re: 4PV00105/OH0121371
PICKETT FENCES
RECONASSANCE INSPECTION
PICKAWAY COUNTY**

Dear Mr. Bogenrife:

This inspection was conducted on June 1, 2009, by Ohio EPA personnel. The purpose of this inspection was to evaluate compliance with the NPDES. At the time of the inspection, the wastewater treatment plant was not acceptable. The sand filters were losing partially treated wastewater through the walls, see attached photograph.

A review of your monthly operating reports shows that you have not reported since September of 2008. In addition your contracted operator has not been at your WWTP since he resigned in August of 2008.

To avoid escalated enforcement, on or before July 1, 2009, provide this office with the maintenance plan for your sand filters, past monthly operating reports and a copy of your contract with your operator of record.

If you have any questions, comments, or concerns, please call me at (614) 728-3847.

Sincerely,

Sheree Gossett-Johnson
Environmental Specialist II
Compliance and Enforcement Unit, Division of Surface Water
Central District Office

SGJ/nsm Pickett Fences 6 09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korfeski, Director

