

SIGNATURE RECEIVED

OhioEPA

7/13/09

FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

**CERTIFIED #91 7108 2133 3932 4449 8218**

July 8, 2009

Mr. Bigham  
85141 Lancaster-Chillicothe Road  
Amanda, OH 43012

Re: **4PW00007 / OH0124010**  
**BIGHAM'S APARTMENTS WWTP**  
**RECONNAISSANCE INSPECTION**  
**PICKAWAY COUNTY**

Dear Mr. Bigham:

This reconnaissance inspection was conducted on July 6, 2009, by Ohio EPA personnel to determine compliance with your NPDES permit effluent limitations.

At the time of the inspection, the wastewater treatment plant (WWTP) did not operate. Manual operation of this WWTP is not acceptable. In addition, your NPDES permit renewal is past due.

To avoid escalated enforcement action, please submit your NPDES permit renewal as soon as possible.

If you have any questions, comments, or concerns, please call me at (614) 728-3847.

Sincerely,



Sheree Gossett-Johnson  
Environmental Specialist II  
Enforcement and Compliance  
Division of Surface Water  
Central District Office

Enclosure

c: **Becky Levernier, R.S.**  
**Pickaway County General Health District**

SGJ/nsm Bigham July 09

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

