

SIGNATURE RECEIVED
OHIO EPA

8/14/08

4PV00116 C

FILE COPY

State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

Certified Mail #91 7108 2133 3932 4450 3547

July 30, 2008

Mr. Robert Toland
55 DeWar Drive
Heath, Ohio 43056

**Re: Suburban Mobile Home Park
Ohio EPA Permit No.: 4PV00116*CD**

Dear Mr. Toland:

This office is in receipt of self-monitoring reports covering the period of time extending from July 1, 2007, through June 30, 2008, for the above referenced facility. The Surface Water Information Management System (SWIMS) has recorded apparent wastewater discharge permit numerical effluent limitations violations. Specific instances of noncompliance are listed in Attachment "A" of this notice of violation.

It should be noted that effluent limitations violations listed in Attachment "A" are of the interim effluent limitations contained in the wastewater discharge permit. Final effluent limitations are more restrictive and become effective July 1, 2009.

Specific instances of noncompliance also include failure to submit plans for improvement of the wastewater treatment plant (WWTP) serving your facility. The improvements are necessary to allow the WWTP to provide consistent compliance with the final effluent limitations.

Please be advised that failure to comply with effluent limitations or to satisfy monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Please inform me, in writing, within ten days of receipt of this notification as to the reasons for the above referenced violations, as well as a description of the actions taken or proposed to prevent any further violations. Your response should include dates, either actual or proposed, for completion of the actions. Your response should also include the name, telephone number and wastewater certification of the operator in responsible charge of this WWTP.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Mr. Robert Toland
Page -2-

This facility has remained in noncompliance for an extended period of time. Please be advised that failure to comply with the effluent limitations or to satisfy the monitoring or reporting requirements of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

If there are questions, I can be reached at (740) 728-3850.

Sincerely,



Jan A. Rice
Environmental Specialist
Field Operations Unit
Division of Surface Water
Central District Office

JAR/nsm Suburban MHP 7-28-08

Attachment "A"

Suburban Mobile Home Park WWTP Effluent Limitations Violations Monitoring Station 4PV00116001 (7/1/07 – 6/30/08)

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
4PV00116*CD	August 2007	001	31616	Fecal Coliform	30D Conc	1000	10000.	8/1/2007
4PV00116*CD	August 2007	001	31616	Fecal Coliform	1D Conc	2000	10000.	8/13/2007
4PV00116*CD	November 2007	001	80082	CBOD 5 day	30D Conc	25	96.	11/1/2007
4PV00116*CD	November 2007	001	80082	CBOD 5 day	30D Qty	0.57	1.12642	11/1/2007
4PV00116*CD	November 2007	001	80082	CBOD 5 day	1D Conc	40	96.	11/12/2007
4PV00116*CD	November 2007	001	80082	CBOD 5 day	1D Qty	0.91	1.12642	11/12/2007
4PV00116*CD	February 2008	001	80082	CBOD 5 day	30D Conc	25	38.	2/1/2008
4PV00116*CD	May 2008	001	31616	Fecal Coliform	30D Conc	1000	5200.	5/1/2008
4PV00116*CD	May 2008	001	31616	Fecal Coliform	1D Conc	2000	5200.	5/12/2008

Suburban Mobile Home Park WWTP Compliance Schedule Violations

Facility	Permit No	App No	Permit Effective Date	Permit Expiration Date	Schedule Due Date	Completion Date	Event Code	Schedule Type	Schedule Milestone
Suburban MHP	4PV00116*CD	OH0130737	7/1/2007	6/30/2012	1/1/2008		1799	Construction	Complete Plans & Specs
Suburban MHP	4PV00116*CD	OH0130737	7/1/2007	6/30/2012	7/1/2008		3099	Construction	Begin Construction

