



**Environmental  
Protection Agency**

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

April 4, 2012

RE: WAYNE COUNTY  
MCDONALD'S RESTAURANT - WOOSTER  
NON-TRANSIENT, NON-COMMUNITY  
PUBLIC WATER SYSTEM  
PWS ID # OH8553912  
STU ID # 8559762

Ms. Teresa Dulemba  
McDonald's Restaurant  
2130 E. Lincoln Way  
Wooster, Ohio 44691

Dear Ms. Dulemba:

On March 12, 2012, this office received the February 2012 Monthly Operating Report (MOR form 5002) from McDonald's Restaurant - Wooster. Operational monitoring is conducted throughout the month to test the treatment effectiveness of the water plant. Since McDonald's Restaurant - Wooster treats its water by softening (hardness removal) and chlorine injection (disinfection); you are required to conduct monitoring for hardness and chlorine residual.

Please note the following violation:

Ohio Administrative Code (OAC) Section 3745-83-01 requires all community and major non-community water systems to maintain a minimum chlorine residual of at least 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine, measured at representative points throughout the distribution system. On nine of 30 days during the month of February 2012, chlorine residuals were reported as less than 0.2 mg/L free chlorine, or 1.0 mg/L combined chlorine.

Please investigate the cause of the low chlorine residuals and work to resolve the issue.

If you have any questions regarding this correspondence, or if you need any assistance, please contact me at (330) 963-1194 or at my e-mail address, [beth.madis@epa.state.oh.us](mailto:beth.madis@epa.state.oh.us).

Sincerely,

Beth R. Madis  
Environmental Specialist  
Division of Drinking and Ground Waters

BRM/ams

cc: Wayne County Health Department