

4IN00053C
FILE COPY



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

May 24, 2010

Mr. Rick Clark
Superior Fibers, Inc.
499 North Broad Street
Bremen, OH 43107

Dear Mr. Clark:

Attached is a report regarding a Reconnaissance Inspection that Greg Sanders and I from this office performed May 13, 2010 at your facility. No problems were noted with the non-contact cooling water discharge from your facility at the time of this inspection.

If you have questions I can be contacted by e-mail at jan.rice@epa.ohio.gov or by telephone at 614-728-3850.

Sincerely,

Jan A. Rice
Environmental Specialist
Field Operations Unit
Division of Surface Water
Central District Office

JAR/nsm Superior Fibers, Inc. 5-13-10Rlcovltr

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



**NPDES
Compliance Inspection Report**

A. NATIONAL DATA SYSTEM CODING

Permit No. 41N00053*FD	NPDES No. OH0055182	Date 5/13/10	Inspection Type R	Inspector S	Facility Type 2
----------------------------------	-------------------------------	------------------------	-----------------------------	-----------------------	---------------------------

B. FACILITY DATA

Name and Location of Facility Inspected Superior Fibers, Inc. P.O. Box 89 499 North Broad Street Bremen, Ohio 43107	Entry Time 1:00 P.M.	Permit Effective Date 5/1/08
	Exit Time 2:20 P.M.	Permit Expiration Date 4/30/13

Name(s) and Title(s) of On-Site Representative(s) James (Rick) Clark, Environmental Technician	Phone Number(s) 740-569-4175
Name(s) Address and Title(s) of Operator of Record	Phone Number(s)
Name, Address and Title of Responsible Official James (Rick) Clark, Environmental Technician, Superior Fibers, Inc. 499 North Broad Street, Bremen, Ohio 43107-0085	Phone Number 740-569-4175

C. AREAS EVALUATED DURING INSPECTION (S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

- S Permit
- S/S Records/Reports
- S Operations & Maintenance
- S Facility Site Review
- N Collection System
- S Flow Measurement - the permittee has been reporting the maximum rather than the actual flow discharged each day. Actual daily flow will be reported on future discharge monitoring reports.
- N Laboratory
- S/S Effluent/Receiving Waters
- N/N Sludge Storage/Disposal
- N Pretreatment
- None Compliance Schedules
- S Self-Monitoring Program

D. SUMMARY OF FINDINGS/COMMENTS: Discharge consists of non-contact cooling water routed into a drainage ditch along the north side of this facility.

Jan Rice
Jan Rice, Inspector, Ohio EPA, Central District Office

5/24/10
Date

Erin Sherer
Erin Sherer, Reviewer, Ohio EPA, Central District Office

5.24.10
Date

Superior Fibers, Inc.
Effluent limitations Violations
Monitoring Station 4IN00053001
5/1/08 - 3/31/10

Permit No	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
4IN00053*FD	March 2009	001	00400	pH	1D Conc	9.0	9.5	3/4/2009
4IN00053*FD	March 2009	001	00400	pH	1D Conc	9.0	9.5	3/5/2009
4IN00053*FD	March 2009	001	00400	pH	1D Conc	9.0	9.5	3/6/2009
4IN00053*FD	March 2009	001	00400	pH	1D Conc	9.0	9.5	3/9/2009
4IN00053*FD	March 2009	001	00400	pH	1D Conc	9.0	9.5	3/10/2009