



State of Ohio Environmental Protection Agency

Central District Office

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

May 1, 2008

Pickaway County Board of Commissioners
139 West Franklin Street
Circleville, Ohio 43113

Re: 4PG00025/OH0036242
NPDES \ PUBLIC
Knollwood WWTP
Pickaway County

Dear Commissioners:

On April 23, 2008, I received a complaint that the Knollwood Village WWTP sewage was overflowing into the adjacent farm field. I inspected the WWTP and found that two of the three sand filters were full, and had appeared to overflow into the farmers field, see attached photographs.

At the time of the inspection, the facility was found to be unacceptable.

Please inform this office, in writing, within ten days of receipt of this notification as to the reason for the overflow, as well as a description of the action taken to prevent any further overflows. In addition, please remove the excess used sand around the sand filters.

If you have any questions or concerns, please call me at (614) 728-3847.

Sincerely,

Sheree Gossett-Johnson
Environmental Specialist II
Enforcement & Compliance Unit
Division of Surface Water
Central District Office

Enclosure

c; John Kinder

SGJ/nsm Knollwood0408

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director