

4P6 00025



State of Ohio Environmental Protection Agency

FILE COPY

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

May 28, 2009

Pickaway County Board of Commissioners
139 West Franklin Street
Circleville, OH 43113

**Re: Knollwood Village WWTP
Reconnaissance Inspection
Pickaway County**

Ladies and Gentlemen:

On May 11, 2008, a Reconnaissance Inspection was conducted at the Knollwood Village Wastewater Treatment Plant (WWTP), by Ohio EPA personnel.

The purpose of the inspection was to evaluate compliance with the terms and conditions of your National Pollutant Discharge Elimination System (NPDES) permit. At the time of this inspection, the plant was operating marginally satisfactorily. The rating of marginal was due to effluent violations. As with Circle Hills, I believe the violations were caused by equipment failures and questionable tank integrity.

At this time to avoid escalated enforcement action, please contact the City of Circleville to connect the Circle Hills collection system to the City's WWTP.

Please keep this office informed as to your progress.

If you have any questions or comments, or need my assistance, please contact me at (614) 728-3847.

Sincerely,

Sheree Gossett-Johnson
Environmental Specialist II
Compliance and Enforcement Section
Division of Surface Water
Central District Office

Sincerely,

c: Mr. Robert E. Parker P.E., P.S., Pickaway County Engineer
Mr. Val Jackson, Kinder Environmental Services, Inc.

c: Knollwood 09

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director