



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

August 9, 2007

Re: 4PT00006/OH0102008
St. Johns Evangelical Lutheran
Church & School
Union County

Mr. David C. Ruff,
Maintenance Director
St. Johns Evangelical Lutheran Church & School
12809 State Route 736
Marysville, OH 43040

Dear Mr. Ruff:


This inspection was conducted on August 7, 2007, by Ohio EPA personnel. At the time of the inspection the facility was unsatisfactory. Your monthly operating reports indicate that the wastewater treatment plant is not treating the wastewater adequately to meet your NPDES effluent limits.

At this time, this office expects you to obtain the services of a Class I contract operator to be the "operator of record" until you are eligible to take the Class I wastewater operator state exam and have passed it. In addition, the contract operator should assist you in the repair and replacement of needed equipment.

Please submit to this office, in writing, on or before August 24, 2007, the name and certification number of the operator of record, and schedule for replacements and repairs for the entire wastewater treatment plant. In addition, I have enclosed a copy of your current NPDES permit, Operation and Maintenance guide for package plant owners and some process control tests to assist you in operating the plant efficiently.

If you have any questions, comments or concerns, please call me at (614) 728-3847.

Sincerely,



Sheree Gossett-Johnson
Environmental Specialist II
Compliance/Enforcement Section
Division of Surface Water

c: Chris Ledley

SGJ/ct St Johns Unio County2007

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director