



**Environmental
Protection Agency**

John R. Kasich, **Governor**
Mary Taylor, **Lt. Governor**
Scott J. Nally, **Director**

April 9, 2012

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
NIMISILA MHP
COMMUNITY WATER SYSTEM
PWS ID # OH7702912

Ms. Michelle Jimenez
1529 Brittain Road #7
Akron, OH 44310

CERTIFIED MAIL

Dear Ms. Jimenez:

This letter is notification that the Nimisila Mobile Home Park (MHP) public water system (PWS) is in violation of Ohio Administrative Code (OAC) Rule 3745-83-02 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Nimisila MHP PWS as reported on Monthly Operating Report (MOR) for the months of January and February 2012.

An evaluation/investigation should be conducted to determine why the low residuals and what corrective action is necessary. Please provide your findings to this writer by April 27, 2012. Include with your findings a map that identifies the locations of the low residuals.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Eppers, Ohio EPA, NEDO, DDAGW