



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

Central District Office

TELE: (614) 728-3778 FAX: (614) 728-3895
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 6, 2009

Steve Heimberger
Crane Plastics Company
2141 Fairwood Avenue
Columbus, OH 43207

**Re: Crane Plastics Company / Franklin County
Industrial Storm Water Permit 4GR00223*DG**

Dear Mr. Heimberger:

This letter is written in regard to the storm water inspection that I conducted at Crane Plastics Company located at 2141 Fairwood Avenue in Columbus, Ohio. The inspection was conducted on July 1, 2009, to determine compliance with your industrial storm water permit. I did not note any discharge from your facility to storm water drains, waters of the state or off of your property. Overall, the facility was well-kept. The following items were noted during the inspection:

- Numerous double-walled tanks on the north-side of the property store and transfer plastic stock for production. There were other tanks located on the property which were also double-walled tanks. No tanks were leaking nor was there evidence of staining of the concrete around the tanks. Drums which contained used oil and coolant were stored under roof. No follow-up action required.

If you have any questions regarding this letter or my inspection, please do not hesitate to contact me at our Central District Office at 614-728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, DSW/CDO

GS/nsm Crane Plastics Company, July 1, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

