



State of Ohio Environmental Protection Agency

**Central District Office**

REET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 10, 2009

Denise Crews  
City of Lancaster  
104 East Main Street  
Lancaster, OH 43130

**Re: SR 185 Water Tank / Fairfield County**

Dear Ms. Crews:

This letter is written regarding the storm water inspection I conducted on July 2, 2009, of the construction activities at the SR 185 Water Tank, at 2357 Rainbow Drive. The Agency understands that these construction activities are currently covered under the General Storm Water Permit Associated with Construction Activities. Based on the site inspection and the General Storm Water Permit, the following was observed or discussed at the site:

**Sediment and Erosion Controls:**

Please be aware that the General Permit mandates that all barren areas which remain idle areas in excess of 21 days be protected from erosion (i.e., seed and straw), within seven days from the last construction activity. Please see attached pictures.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders  
Environmental Specialist  
Division of Surface Water  
Central District Office

Enclosure

c: Jeff Bohne, DSW/CDO

GLS/nsm SR 185 Water Tank, July 2, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

12





