



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 13, 2009

James Page
Page Engineering Inc
112 East Fifth Street
P.O. Box 394
Marysville, OH 43040

Re: Storm Water Inspection at Memorial Hospital of Union County

Dear Mr. Page:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Sean Tyler of the Ohio EPA, at Memorial Hospital of Union County located at 708 South Plum Street in Marysville, Ohio on July 6, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Site appears to be near completion at date of inspection. Continue to maintain sediment and erosion controls.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review. **Please submit your log for review.**

Post Construction Requirements:

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction mandates are found at: [Http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html](http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html). Please submit to my attention (email preferred at harry.kallipolitis@epa.state.oh.us) which practice will be installed at this site to ensure compliance with the General Permit. Please be sure to include all design criteria and calculations in your submission.

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

James Page
Page Engineering Inc
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Memorial Hospital of Union co July 6, 2009