



State of Ohio Environmental Protection Agency

Central District Office

TELE: (614) 726-3778 FAX: (614) 726-3898
www.epa.state.oh.us

REET ADDRESS:

LeZarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

July 13, 2009

Tim Cullinan
Willoway Nurseries
4534 Center Road
P.O. Box 299
Avon, OH 44011

Re: Storm Water Inspection at Willoway Nurseries

Dear Mr. Cullinan:

This letter is written in follow-up to a construction storm water inspection by Ryan Griffin and Sean Tyler of the Ohio EPA, at Willoway Nurseries located at the Southside of Scioto Darby Creek Road in Brown Township, Franklin County, Ohio on July 6, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls:

- Site appears to be in compliance. Sediment ponds appear to be working properly.
- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Willoway Nurseries July 6, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korieski, Director

