



State of Ohio Environmental Protection Agency

RECEIVED ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 21, 2009

Michael Murphy
Murphy Development Company
4393 Arbor Lake Drive
Groveport, OH 43125

Re: Cobbleton Grove / Franklin County

Dear Mr. Murphy:

This letter is written regarding the storm water inspection that I conducted at Cobbleton Grove, located along Ebright Road, in Franklin County, on July 16, 2009. I understand that these construction activities are covered under the General Storm Water Permit Associated with Construction Activities. Based on my site inspection and the General Storm Water Permit, the following items must be addressed:

Sediment and Erosion Controls:

Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review. Please see attached picture.

If you have any questions regarding this letter or my inspection, please do not hesitate to call me at our Central District Office at (614) 728-3851.


Sincerely,

Gregory L. Sanders
Storm Water Unit
Division of Surface Water
Central District Office

Enclosure

GS/nsm Cobbleton Grove Condos, July 16, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



Cobbleton Grove Condos
Maintain dandy bags
Blackfoot Creek Watershed
July 16, 2009
Photo by: Greg Sanders



