OhioEPA
State of Ohio Environmental Protection Agency
Central District Office

STREET ADDRESS:
Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898
www.epa.state.oh.us

MAILING ADDRESS:
P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

John Kletrovetz
Dominion Homes, Inc.
5501 Frantz Rd.
Dublin, OH 43017

Re: Village at Courtright Square / Franklin County

Dear Mr. Kletrovetz:

This letter is written in follow-up to a construction storm water inspection I conducted at the Village at Courtright Square located near the intersection of Refugee Road and Courtright Road on July 13, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- Upon inspection, the sediment and erosion controls appear to be in compliance with the requirements of the General Storm Water Permit.

- Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3851.

Sincerely,

Gregory L. Sanders
Environmental Specialist
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

GS/nsm Village at Courtright Square, July 13, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

Printed on Recycled Paper

Ohio EPA is an Equal Opportunity Employer