



State of Ohio Environmental Protection Agency

**Central District Office**

REET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2009

Steve Morley  
Transamerica Building Company Inc.  
2000 West Henderson Road  
Columbus, OH 43220

**Re: Construction Storm Water Inspection at Lyon Video Inc.**

Dear Mr. Morley:

This letter is written in follow-up to a construction storm water inspection Ryan Griffin and Sean Tyler, of Ohio EPA, conducted at Lyon Video Inc. located at 2091 Arlingate Lane in Columbus, Ohio on July 6, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, the following was noted:

**Sediment and Erosion Controls**

- It appears the recently installed perimeter silt fence for this site is working as intended. Please be aware that the General Permit indicates that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.

**21 Day Rule**

- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days.

**Post Construction Requirements:**

The General Storm Water Permit requires specific post construction water quality treatment for all sites. Guidance regarding the post construction requirements is found at: <http://www.epa.state.oh.us/dsw/storm/CGP-PC-Q&A.html>. Please submit to my attention (email preferred at [harry.kallipolitis@epa.state.oh.us](mailto:harry.kallipolitis@epa.state.oh.us)) which practice will be

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Steve Morley  
Page 2

installed at this site to ensure compliance with the General Permit. Please include all design criteria and calculations in your submission.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO



**Figure 1 Current Construction Activities**

7. 2. 2.

