



State of Ohio Environmental Protection Agency

**Central District Office**

TELE: (614) 728-3778 FAX: (614) 728-3898  
www.epa.state.oh.us

**PHYSICAL ADDRESS:**

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

**MAILING ADDRESS:**

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2009

Mark D. Bartel  
Schorr Architects, Inc  
230 Bradenton Avenue  
Dublin, OH 43017

**Re: Storm Water Inspection at Millersport High School- #4GC02752\*AG**

Dear Mr. Bartel:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at Millersport High School located on Lancaster Street in Millersport, OH on Wednesday, July 1, 2009. The purpose of the inspection was to evaluate compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Barren Areas: 21 Day Rule**

- The sediment and erosion controls on site appear to be functioning properly. However, please be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. Erosion protection must be provided for all areas of final grade within seven days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/mjs Millersport High School July 1, 2009

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

