



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 728-3778 FAX: (614) 728-3896
www.epa.state.oh.us

P.O. Box 1049
Columbus, OH 43216-1049

July 22, 2009

Charles Driscoll
Tartan Ridge Associates LLC
495 South High Street, Suite 150
Columbus, OH 43215

Re: Tartan Ridge Section 1/Permit #4GC02310*AG

Dear Mr. Driscoll:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at Tartan Ridge located between Brock, Jerome, McKitrick, and Hyland-Croy Roads in Union County on July 9, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

Sediment and Erosion Controls

- The inlet at Burnett and Tartan Ridge requires protection.
- The inlet protection on site requires maintenance to ensure proper functioning.
- It was apparent that the dirt pile on Enfield Trace is barren. Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven days.

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,

Harry Kallipolitis
Storm Water Coordinator
Division of Surface Water
Central District Office

c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/mjs Tartan Ridge July 9, 2009

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

