



State of Ohio Environmental Protection Agency

REET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center  
50 W. Town St., Suite 700  
Columbus, Ohio 43215

TELE: (614) 728-3775 FAX: (614) 728-3998  
www.epa.state.oh.us

P.O. Box 1049  
Columbus, OH 43216-1049

July 22, 2009

Robert P. Alexander  
Mount Gilead Exempted Village School District  
145 ½ North Cherry Street  
Mount Gilead, OH 43338

**Re: Storm Water Inspection at Mount Gilead High and Middle Schools  
Permit #4GC02741\*AG**

Dear Mr. Alexander:

This letter is written in follow-up to a construction storm water inspection by Katie Anderson and Rachelle Howe, of the Ohio EPA, at Mount Gilead High and Middle Schools located at 338 West Park Avenue in Morrow County on July 6, 2009. The purpose of the inspection was to ensure continued compliance with the General Storm Water Permit Associated with Construction Activities. During the inspection, we noted the following:

**Sediment and Erosion Controls:**

- An inlet appeared to be unprotected (see Photo Figure 1). This inlet requires protection or demonstrate an approvable alternative.
- The inlet protection on site requires maintenance to ensure proper functioning condition (see Photo Figure 2). This general permit states that all sediment controls will be inspected and maintained every seven days or within 24 hours of a precipitation event equal to or greater than 0.5 inches. A log of inspection must be maintained on site for the agency to review.
- Be aware the General Permit states that all barren areas which remain idle in excess of 21 days must be protected from erosion within seven days of the last earth disturbing activities. In addition, erosion protection must be implemented for all areas of final grade within seven (7) days.

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

Robert P. Alexander  
Mount Gilead Exempted Village School District  
Page -2-

If you have any questions regarding this letter or the inspection, please do not hesitate to contact me at our Central District Office at (614) 728-3844. Follow-up inspections will be conducted to ensure the conditions of the General Permit are continuing to be met.

Sincerely,



Harry Kallipolitis  
Storm Water Coordinator  
Division of Surface Water  
Central District Office

Enclosure


c: Jeff Bohne, Water Quality Supervisor, DSW/CDO

HK/nsm Mt. Gilead High and Middle Schools July 6, 2009



Mount Gillett Middle and High Schools  
Alum Creek Watershed  
Photo by: Katie Anderson  
July 6, 2009

Figure 1



Mount Gillett Middle and High Schools  
Alum Creek Watershed  
Photo by: Katie Anderson  
July 6, 2009

Figure 2

